

*VILLAGE OF ALBANY 2025
CONSUMER CONFIDENCE
REPORT*



The Village of Albany
Drinking Water Consumer
Confidence Report for 2025

INTRODUCTION

The Village of Albany has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. This report was required as part of the Safe Drinking Water Act Reauthorization of 1996 and is required to be delivered to the consumers by July 01, 2025. Included is the Le-Ax Water District Consumer Confidence Report for 2025 within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water systems contacts.

What's The Source of Your Drinking Water?

The Village of Albany purchases all its water from the Le-Ax Water District. The Le-Ax Water District obtains its drinking water from a horizontal collector well located approximately 200 ft. south of the Hocking River in the northeast corner of section 32 of Dover Township, Athens County, and The State of Ohio. It pulls its water from the Hocking River Aquifer.

How Do I Participate In Decisions Concerning My Drinking Water?

Public participation and comment are encouraged at regular meetings of the Village Council. If you have any questions regarding this report, or any other matter regarding our drinking water, you may contact the Village of Albany Water Department at (740) 698-6127. Also, if you have any questions concerning the Le-Ax Water District contact Lonny McCulloch or Mike Riley at (740) 593-7502.

About Your Drinking Water

The EPA requires regular sampling to ensure drinking water safety. The Village of Albany conducted sampling for bacteria, lead, copper, TTHM and HAA5 in 2025. In addition, according to the enclosed consumer confidence report the Le-Ax Water District conducted sampling for (bacteria, volatile organic, total trihalomethanes, and other unregulated) contaminants in 2025. Listed on back is information on those contaminants sampled in the Village of Albany water supply.

License to Operate (LTO) Status Information

We have a current, unconditioned license to operate our water system.

VILLAGE OF ALBANY
2025 CONSUMER CONFIDENCE
REPORT

Drinking Water Consumer Confidence Report for 2025

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Sample Year	Violation	Typical Source of Contaminants naturally present in the environment
Total Coliform	0	1	0	NA	2025	NO	

A public water system which monitors with less than forty samples per month is in compliance with The maximum contaminant level for total coliforms when no more than one sample during the month is determined to be total coliform-positive.

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Sample Year	Violation	Typical Source of Contaminants
Chlorine (ppm)	4	4	0.973333	0.90-1.15	2025	NO	Water additive used to control microbes

Inorganic Contaminants

Contaminants (Units)	Action Level(AL) over AL	Individual Results	90% of test levels were less than	Sample Year	Violation	Typical Source of Contaminants
Lead (ppb)	15 ppb	0	<2.0 (less than detectable)	2025	NO	Corrosion of household plumbing systems; erosion of Natural deposits.
Copper (ppm)	1.3 ppm	0	0.026	2025	NO	Erosions of Natural deposits; leaching from wood preservatives; corrosion of household plumbing.

(0 out of 10 samples were found to have levels in excess of the cooper action level of 1.3 ppm.)

Volatile Organic Contaminants

Trihalomethanes (ppb)	NA	80	45.68	33.2-50.9	2025	NO	By-product of drinking water chlorination
Halo acetic Acids product of (ppb)	NA	60	9.37	6.2-11.5	2025	NO	By-product of drinking water chlorination

If present, elevated levels of lead can cause serious health problems, especially for pregnant woman and your children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Albany is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. Why your water has been setting for several hours, you can minimize the potential for lead exposure by flushing your tap 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps, you can take to minimize exposure to available from the Safe Drinking Water Hotline at:

1-800-426-4791 or <http://www.epa.gov/safewater/lead>.

Maximum Contaminant Level Goal (MCLG) – The level of contaminant in drinking water below there is no known or expected risk to health.

Maximum Residual Disinfection Level Goal (MRDLG) – The level of drinking water disinfectant below which there is no known expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per Million (ppm) – Are units of measurement for the concentration of a contaminant. A part per million corresponds to one second in approximately 11.5 days.

Parts per Billion (ppb) – Are units of measurement for the concentration of a contaminant. A part per billion corresponds to one second in approximately 31.7 years.

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

The "<" symbol – A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and contaminant in that sample was not detected.

"NA" – means "Not Applicable"

Le-Ax Regional Water District

2025 Consumer Confidence Report

Introduction

The Le-Ax Regional Water District has prepared the following report to provide information to the consumer on the quality of its drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

Source Water Information

The Le-Ax Regional Water District receives its drinking water from two horizontal collector wells located near the Hocking River in Dover Township, Athens County, Ohio.

A susceptibility analysis was completed by Ohio EPA, which identifies potential contaminant sources in and around this area. According to this study, the aquifer (water-rich zone) that supplies water to Le-Ax Regional Water District has a HIGH susceptibility to contamination. This does not mean that the well field will become contaminated, only that the likelihood of contamination is relatively high.

This determination is based on the following:


- Lack of protective layer of clay overlaying the aquifer,
- Shallow depth (less than 15 feet below ground surface) of the aquifer; and
- The presence of significant potential contamination sources in the protection area

This susceptibility rating means that under current existing conditions, the likelihood of the aquifer becoming contaminated is high. This likelihood can be minimized by implementing appropriate protective measures. Le-Ax Regional Water District has developed a Source Water Protection Plan to protect the aquifer that supplies our drinking water from land-based contamination. Components of the Protection Plan include contaminant source control strategies, education and outreach strategies, and contingency plan updates. More information about the source water assessment or what consumers can do to help protect the aquifer is available by calling Robert Peck at (740) 593-7502.

What are sources of contamination to drinking water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of



industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Federal Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

What can you do to avoid contamination to drinking water?

Use and Dispose of Harmful Materials Properly

Do not pour hazardous waste down the drain, on the ground, or into storm sewers. This could contaminate the soil, groundwater, or nearby surface water.

A number of products used at home contain hazardous or toxic substances that can contaminate ground or surface waters, such as:

- Motor oil
- Pesticides
- Leftover paints or paint cans
- Mothballs
- Flea collars
- Household cleaners
- Many medicines

Think Twice about Lawn and Garden Chemicals

Limit the use of pesticides or fertilizers, and always follow the label directions. Many fertilizers and pesticides contain harmful chemicals which can travel through the soil and contaminate groundwater or run off in stormwater to rivers, streams, and lakes. EPA evaluates pesticides to ensure that when they are used according to label directions.

Properly Maintain Your Septic System

Groundwater can be contaminated by poorly or untreated household wastewater, which poses dangers to drinking water and the environment. Malfunctioning septic systems release bacteria, viruses, and chemicals to local aquifers and waterways. The average household septic system should be inspected at least every three years. Alternative systems with electrical float switches, pumps, or mechanical components should be inspected more often, generally once a year. Household septic tanks are typically pumped every three to five years.

Dispose of Your Medications Properly

In homes that use septic tanks, prescription and over-the-counter drugs flushed down the toilet can leach into the ground and seep into groundwater. In cities and towns where residences are connected to wastewater treatment plants, prescription and over-the-counter drugs poured down the sink or flushed down the toilet can pass through the treatment system and enter rivers and lakes. These water sources may flow downstream to community drinking water supplies. Water treatment plants are generally not equipped to routinely remove medicines.

EPA encourages the public to take advantage of pharmaceutical take-back collection programs that accept prescription or over-the-counter drugs, as these programs offer a safe and environmentally-conscious way to dispose of unwanted medicines.

Cross-connection and Backflow

Cross-connection is any physical connection created between a possible source of contamination and any drinking water system piping. An example of a cross-connection would be a well pump that is also connected to the interior plumbing of a home that the public water system serves. Another example of cross-connection would be a hose with one end submerged in a pool, hot tub, or watering trough, and the other end secured to a yard hydrant, spigot or hose bib.

Backflow is the flow of a contaminant through a cross-connection into the drinking water system. This occurs when a cross-connection is created and a pressure reversal, either as backsiphonage or backpressure, occurs in the water supply piping. This can happen when there is a water main break. If the pressure of the source of contamination is greater than the water system pressure, contaminated water may backflow into the drinking water system. Pressure drops in the public water system caused by water line breaks, pump failures, and fire-fighting can also cause a backflow situation.

For more information on cross-connection hazards and backflow prevention, please click the link ***Backflow Prevention Program*** on our website at <https://le-ax.com>.

Who needs to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

About your drinking water

The EPA requires regular sampling to ensure drinking water safety. The Le-Ax Regional Water District conducted sampling for bacteria, nitrate, lead, copper, disinfection products and disinfection by-products during 2025. The Ohio EPA requires Le-Ax to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change readily over time. This is the reason that some data may have been sampled more than one year ago. Listed below is information on those contaminants that were found in the Le-Ax Regional Water District's drinking water.

Table of Detected Contaminants

Contaminant (units)	MCLG or MRDLG	MCL or MRDL	Level Found	Range of Detections	Violation?	Year Sampled	Typical Source of Contaminants
Inorganic Contaminants							
Arsenic (ppb)	0	10	<3.0	N/A	No	2023	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium (ppm)	2	2	0.039	N/A	No	2023	Discharge of drilling waste; discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	1.01	0.87-1.24	No	2025	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (ppm)	10	10	<0.10	N/A	No	2025	Runoff from fertilizer use; Leaching from septic tanks, sewers; Erosion of natural deposits
Residual Disinfectants and Disinfection Byproducts							
Chlorine (ppm)	4	4	1.13	0.90-1.62	No	2025	Water additive used to control microbes
Total Trihalomethanes (TTHM) (ppb)	N/A	80	43.02	24.5-83.3	No	2025	By-product of water chlorination
Haloacetic Acids (HAA5) (ppb)	N/A	60	6.05	0-11.1	No	2025	By-Product of drinking water chlorination
Lead and Copper							
Contaminant (units)	Action Level (AL)	MCLG	Individual Results over the AL	90 TH Percentile Value	Violation?	Year Sampled	Typical Source of Contaminants
Lead (ppb)	15	0	0	2.48	No	2025	Corrosion of household plumbing systems; erosion of natural deposits
	0 out of 30 samples were found to have lead levels in excess of the lead action level of 15 ppb.						
Copper (ppm)	1.3	1.3	0	0.903	No	2025	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems
	0 out of 30 samples were found to have copper levels in excess of the lead action level of 1.3 ppm.						

The table below lists typical results for drinking water that is delivered to the consumer.

Typical Finished Water Test Results		Maximum Allowable
Hardness	130-160 ppm (7.6-8.8 grains/gal)	N/A
pH	7.2-8.0	N/A
Free Chlorine (distribution)	0.2-1.2 ppm	0.2 ppm min, 4.0 ppm max
Iron	<0.010 ppm	0.30 ppm
Manganese	<0.010 ppm	0.05 ppm
Alkalinity Stability	neutral, slightly depositing	N/A
Fluoride	0.87-1.24 ppm	2.0 ppm
Sodium	100-125 ppm	N/A

Lead Educational Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Le-Ax Regional Water District is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 800-426-4791 or at <http://www.epa.gov/safewater/lead>.

The 2021 EPA Lead and Copper Rule Revisions required public water systems to develop a complete inventory of all service lines. Initially, Le-Ax identified the materials of both public and private portions of the service lines by using historical records and customer surveys. A “known service line” is defined as a service line where the pipe material is categorized using records or other means. An “unknown service line” is defined as a service line of unknown material with no documented material history. Additionally, Le-Ax performed a statistical analysis, which provides a method to complete a service line inventory while eliminating or prioritizing the need to inspect every “unknown service line”. Statistical Modeling is an identification method that uses the composition of known service lines to predict the material of unknown service lines in a service area. To do this with a statistically significant result, a large enough sample of randomly selected service lines were identified to ensure that a 95% confidence interval is delivered. In Le-Ax’s group of randomly selected samples, no service lines were identified as lead. Based on this analysis, Le-Ax can make the determination that its distribution system contains no lead, galvanized requiring replacement, or “lead status unknown” service lines.

License to Operate (LTO) Status Information

In 2025 Le-Ax Regional Water District had an unconditioned license to operate its water system.

Public Participation and Contact Information

Public participation and comments are encouraged at regular meetings of Le-Ax Regional Water District, which meet on the 2nd Monday of every month at 4:30 pm. Le-Ax Offices are located at 6000 Industrial Drive, Athens, Ohio. For more information on your drinking water contact Robert Peck at (740) 593-7502.

Definitions of some terms contained within this report

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **The “<” symbol:** A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.
- **Not Applicable (N/A):** Abbreviation meaning that this does not apply to our report.
- **Parts per Billion (ppb) or Micrograms per Liter (µg/L)** are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.
- **Parts per Million (ppm) or Milligrams per Liter (mg/L)** are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.
- **PFAS:** Per- and polyfluoroalkyl substances (PFAS) are a group of man-made chemicals applied to many industrial, commercial and consumer products to make them waterproof, stain resistant, or nonstick. PFAS are also used in products like cosmetics, fast food packaging, and a type of firefighting foam called aqueous film forming foam (AFFF) which are used mainly on large spills of flammable liquids, such as jet fuel. PFAS are classified as contaminants of emerging concern, meaning that research into the harm they may cause to human health is still ongoing.

“This institution is an equal opportunity provider and employer.”